

ADDENDUM #1

Issue Date: April 29, 2024

**Project Name: Griffin Hospital Generator and Distribution System Upgrades
Phase 1 – Fuel Tank Replacement**

Project No.: 2021144.01

GENERAL:

Modifications described herein as Addendum items supersede specific parts of the Contract Documents for the above-named project. All bids and the construction contract shall be based on the inclusion of these modifications.

REVISIONS TO DRAWINGS

- ITEM 1: On Drawings M100.1, M200.0, M300.0, **CLARIFICATION** that the wiring for the fuel tank monitoring system from the fuel oil tank shall be brought to the Fuel Tank Monitoring System Panel in the Generator Room which is part of the scope of this project.
- ITEM 2: On Drawing #M300.0 MECHANICAL FUEL OIL SYSTEM ONELINE AND SCHEDULES, **CLARIFICATION** that top (2) pipes entering the building shall be 1-1/2" FOS&R and the lower (2) pipes shall be 2" FOS&R.

REVISIONS TO PROJECT MANUAL

- ITEM 3: In Section 231113 FACILITY FUEL-OIL PIPING, Paragraph 3.18 FIELD QUALITY CONTROL, **ADD** new sub-paragraph F reading:
- F. Provide to Griffin Healthcare, information required by State of Connecticut E-Z File for UST filing and registration. Actual registration will be performed by Griffin Healthcare.**

VANZELM
E N G I N E E R S

VAN ZELM HEYWOOD & SHADFORD, INC.

10 TALCOTT NOTCH FARMINGTON, CT 06032-1800

P: 860.284.5064

F: 860.284.5098

Connecticut | Massachusetts | North Carolina

END OF ADDENDUM

Document1